

Block Creek Aerobic Services, LLC

444 A Old Hwy No 9
Comfort, TX 78013

(830) 995-3189

Cell Phone: (210) 995-3234

Alternate Cell: (210) 218-6252

Agency: Comal County

Matthew & Lisa Brooks

**2194 Ranch Loop Drive
New Braunfels, TX 78132**

Site Address: 2194 Ranch Loop Drive, New Braunfels Permit #: 101794

System Info: MFG: Advantage Wastewater LLC Brand: Nu Water

ID: 2485

Treatment Type: Aerobic With Chlorine Disposal Type: Surface Application

Insp ID: 198795

Installed: 3/26/2014

Warranty Expiration: 3/26/2017

System S/N: 2169

Visit Details

Visit Date: 7/6/2026

Entered By: Jason K Stanberry

GPS Lat: 29.7915 GPS Long: -98.0797

Scheduled Date: 7/28/2026

Contract Starts: 3/28/2026

Customer Emailed: 7/6/2026



Entered On: 7/6/2026

Contract Ends: 3/28/2027

Visit Results

Service Type: Scheduled Inspection

Printed: 7/6/2026

Count: Inspection 1 of 3

Method: Grab

License #

Expires

Technician: Jason K Stanberry

MP0002388

11/30/2027

Provider: Rudy Carson

MP0002036

11/30/2028

☒ Service Completed

Aerators: Operational

Sludge Level Tank 1: 12"

Filters: Operational

Sludge Level Tank 2: 0"

Irrigation Pumps: Operational

Sludge Level Tank 3: 0"

Disinfection Device: Operational

Chlorine Supply: Operational

Floats: OP

Chlorine Residual: .34

Timer: OP

Tank Lid / Riser: Secured

Electric Circuits: Operational

Distribution System: Operational

Drip/Sprayfield Veg: Operational

Alarm: Operational

Comments

- Technician Secured the Tank Lid and/or Riser prior to leaving location. - Cleaned compressor filter - Scum in pretreatment is 1" Pulled pump and cleaned screen, retied timer float due to being off. Retied all floats. Sprinklers spraying good and rotating. Compressor pushing good air and rolling good in aeration. - Copy emailed to the customer on 7/6/2026. - Copy emailed to the customer on 7/6/2026.

Provider:

Rudy Carson

Technician: Jason K Stanberry

License: Number: MP0002036 Exp: 11/30/2028

License: Number: MP0002388 Exp: 11/30/2027