



Emailed
5-20-26

May 20, 2026

Graham Strom
9735 Fortune Ridge Dr.
San Antonio, Texas 78109

Subject: Final inspection for 9735 Fortune Ridge Dr., Converse, Texas 78109

Dear Graham:

This letter certifies that the foundation repairs were completed in March 2026 at the above-captioned structure. The slab foundation was leveled by installing Fifteen (15) NEW DOUBLE hydraulically placed 6" solid concrete piers by following ASCE (American Society of Civil Engineers) Guidelines.

For the foundation warranty to remain valid, owners must have the drainage system assessed, maintain it, and maintain a leak-free plumbing system. During drought, it is recommended that the plumbing be tested annually and at least every two years.

Respectfully,

Ernie G. Arredondo, P. E.
Acting by and Through It's
General Partner, AGI, LLC.

Signed and sealed electronically



Arredondo Group, LP F-18378

9735 Fortune Ridge

